

Emission Test Certificate

Wednesday January 20th, 2021

Supplier: WCCI Pty Ltd T/As West Coast Commercial Industries (33 Morgan Street, ROCKINGHAM, WA, 6168, Australia)

Sample Description: 13mm Standard Maica Compact Laminate

Date Tested: January 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (7 days exposure):

<p>Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>13mm Standard Maica Compact Laminate</p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.010 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: ≤ 0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.040 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Tuan Duong
B Eng. (Chem.)
Senior Consultant

V2012034